

# 2020-81782 Document Routing Request

Print View Edit Log

**Created on:** 12/4/2020 4:07:33 PM **Status:** EDR request completed.  
**Requestor:** [REDACTED] **Department:** Electric Planning and Strategy  
**Document Type:** AA (Advance Authorization) **Readable by All:** Yes  
**Document Title:** AA -08W - Bucks Creek 1101 - CPZ CB  
**Dollar Amount:** \$950,000  
**Job Order Num:** 35217268  
**Reference Document #:** [2020-81775](#)  
**ITWR Number:**  
**Major Work Category:** 08W

Documents		Reviewers/Approvers	
Title	Version	Reviewers	
<a href="#">Bucks Creek 1101 CB RaDa Model.pptx</a>	Original	[REDACTED]	Approved on 12/16/2020 3:18:50 PM
<a href="#">2021 08W AA Bucks Creek 1101 CB.doc</a>	Original	<b>Approvers</b>	
<a href="#">2021 08W - BucksCreek1101-CB - WorkDescription.pdf</a>	Original	[REDACTED]	Approved on 12/18/2020 9:42:06 AM
<a href="#">Bucks Creek 1101 CB Unit Cost Rev1.xlsx</a>	Original	[REDACTED]	Approved on 12/19/2020 11:35:53 AM
<a href="#">Bucks Creek 1101 CB.kmz</a>	Original	[REDACTED]	Approved on 12/21/2020 1:20:16 PM
<a href="#">2021 08W - BucksCreek1101-CB - Project Scope.pdf</a>	Original	<a href="#">Hide CC List</a>	
<input type="button" value="Consolidate Files"/>		[REDACTED]	

**Comments**

12/18/2020 9:41:52 AM - [REDACTED]  
 Concurring with [REDACTED] comment. In the future, Bucks Creek 1101 becomes part of the Bucks Creek 1103 Circuit.  
 12/16/2020 7:59:30 AM - [REDACTED]  
 Per discussion with DEs, updated design documents to reflect the distribution substation re-configuration and combining BC 1101 into BC 1103 (PM# [REDACTED])  
 12/11/2020 3:48:46 PM - [REDACTED]  
 added cost spreadsheet  
 12/4/2020 4:17:46 PM - [REDACTED]  
 Bucks Creek 1101 in Protective zone CB was identified for system hardening as part of 2021 plan. This project will replace 4.8 miles of overhead line with level 1 and level 3 hardening. There is an existing EDRS #2020-81775 with the proposed project scoping for DE review.